

PERFORMANCE IMPROVEMENT OF OLD DISTRIBUTION TRANSFORMER ASSETS



Report on Active Repair for Performance Improvement of Old Distribution Transformer for
TANGEDCO

February 2020

Contents

1. About the Research Concept.....	2
2. About the pilot.....	3
3. Methodology	4
4. Timelines.....	5
5. Repair Execution for performance improvement of 100 KVA old DT	6
6. Key Observations	14
7. Key Recommendations	15
8. Applicability to broader TANGEDCO Utility	16
Annexures	18
Annexure-1: MoU signed between TANGEDCO and ICAI	18
Annexure 2: Snapshot of Pre-Repair Test Report conducted at NABL	21
Annexure 3: Snapshot of Post Repair test report conducted at NABL for 100 kVA DT	26
Annexure 3.a: Snapshot of Post Repair test report conducted at NABL for enhanced kVA capacity (108 kVA).....	30
Annexure-4: Cost Benefit Analysis	35
Annexure-5: Sensitivity to Cu Salvage value at the end of service	37
Annexure-6: Energy Efficiency Level as per IS 1180:2014	38
Annexure-7: Applicability to broader TANGEDCO Utility	39
Acknowledgement	40

List of Figures

Figure 1. Acquiring conventionally repaired DT-----	7
Figure 2. Dismantling and inspection of transformer -----	7
Figure 3. Pre-repair condition of coil -----	7
Figure 4. Pre-repair coil sectional view -----	7
Figure 5. NABL Pre-repair Testing with TANGEDCO representatives -----	8
Figure 6. TANGEDCO representative & team recording the data -----	8
Figure 7. LV winding -----	8
Figure 8. HV winding-----	8
Figure 9. Core and coil assembly -----	9
Figure 10. Final repaired DT ready for post repair testing-----	9
Figure 11. Setting up connections for testing -----	9
Figure 12. Post Repair testing and recording measurements -----	9
Figure 13. Post Repair Testing at NABL lab-----	10
Figure 14. Setting up connections for enhanced capacity testing at NABL -----	10
Figure 15. Testing at NABL on 13-12-2019 SE R&D with the team -----	10
Figure 16. Testing at NABL on 12-12-2019 CE R&D with the team -----	10
Figure 17. Testing for enhanced capacity testing at NABL -----	10
Figure 18. Final repaired DT ready for reconnecting in the network -----	10
Figure 19. Collecting Active Repaired DT from NABL lab -----	11
Figure 20. Removing existing DT for replacing it with Active Repaired DT -----	11
Figure 21. Connecting Active Repaired DT back into the DT at Chengalpet Electricity Distribution Circle	12
Figure 22. APFC Panel and Energy Meter connected at pole-----	12

List of Tables

Table 1. Key Baseline Parameters of Distribution Transformer-100kVA-----	6
Table 2. Design Solution finalized for ActiveRepair-100kVA-----	6
Table 3. Comparative Pre and Post repair results -----	11

1. About the Research Concept

Transformers play a crucial role in the power distribution network. After overhead distribution lines, transformers are the second largest loss-making equipment in electricity networks. Distribution Transformer (DT) is one of the critical and high value CAPEX assets for DISCOMs. For overall DISCOM viability, it is important that each DT must turn into a profit centre. It is estimated that out of 20%¹ national average AT&C losses, at least 3-4%² comes from Technical losses in DTs, and it can be brought down to 0.5% and below. Earlier RAPDRP program envisaged feeder energy audits however, there was no separate loss estimation for DT alone. Unfortunately, DT technical losses are not generally measured unless it breaks down and only broken-down DTs are sent for repair. There is minimum to none pro-active asset management approach to DT, it's repair and O&M.

DT failure rate is one of the important Key Performance Indicator (KPI) for Indian DISCOMs. The losses associated with DT failure are relatively higher in the Indian context compared to the global benchmark. In India, 12-15%³ DTs fail every year and average rate of failure of aluminium wound DTs is more than copper wound DTs. Overloading is cited as one of the root causes of DT failure besides various other reasons. DTs are frequently overloaded during seasons than their actual capacity resulting in deterioration of their operating health and eventually its lifespan. Any failure of the DT before the expiration of its designed lifespan (25 years by CEA guideline⁴) results in an unplanned outage, production loss, unavailability of critical services and in most cases substantial financial losses to both utilities and customers. Overall, it affects the reliability of the network.

Considering the current financial state of DISCOMs, performance improvement in DT becomes a crucial factor in protecting DISCOMs from further losses. Currently, due to lack of funds to procure new DTs, utility operates the DTs beyond their useful life by inefficiently repairing it several times, resulting in lower efficiency of operation. All these result in reduced efficacy of DTs and high technical losses in the distribution system. Therefore, DISCOMs need to utilize their existing old DTs cost-effectively to get the best out of it. There is a need to save the DISCOMs from the financial burden of investing in the procurement of new DTs to meet the currently growing energy demand.

Realizing the need to improve reliability of DTs, one opportunity to be explored is by improving the performance of DTs through better-quality repair practices. The proposed performance improvement repair practice will give new extended life to the old DTs and enhance their performance equivalent to Energy Efficiency Levels specified by BIS. In this context, a Proof of Concept (PoC) was carried out at TANGEDCO on a 100 kVA DT for performance improvement repair options.

¹ [UDAY Portal](#)

² Based on multiple primary interactions with industry experts

³ Presentation made before CEA 28th Feb 2019 based on study conducted by Frost & Sullivan

⁴ [Standard Bidding Document of DDUGVY under Guidelines for Distribution Utilities for development of Distribution Infrastructure, Page 45, June 2018](#)

2. About the pilot

A proposal to utility for proof of concept (PoC) is submitted on the pilot focuses on developing a mass replicable approach to undertake repairs of legacy DTs (old or conventionally-repaired failed DTs) coming for service and bring down the technical losses and enhance reliability. With mass replicability objective, the core, if healthy, is decided to be kept unchanged and all correction to be effected through windings redesign and/or change of material. The core is restacked tightly to reduce air gaps between laminations.

Under this PoC (confirmed by utility under its MoU dated 21st October 2019 – annexure 1), pre-repair testing, repair execution & post-repair testing activities were conducted at places (including the NABL lab) suggested by TANGEDCO under its (R&D Dept) direct supervision. The Repair involved correcting loss levels of the DT & bringing it closer to the ideal values as specified by Indian Standards for similar type of DTs. After conducting baseline measurement, different design solutions were worked out, post which Repair was undertaken based on optimum design that is techno commercially viable.


No Load Losses, Full Load Losses and Temperature Rise Tests were carried out under the supervision of TANGEDCO representative and ICA experts. Technical loss reduction and post repair kVA capacity enhancement was further validated by NABL accredited lab tests. Experts & team recorded data for analysis of No-load loss & Full load loss post repair and some key conclusions were made as mentioned below:

- Reduces technical losses, thereby saving power costs
- Improves efficiency of transformers, a key component of distribution network stated in the objective of BEE in PAT-2 cycle
- Improves transformer reliability, thereby reducing downtime
- Increases kVA capacity of the transformer that helps DT sustain overloading condition; thus, deferring fresh capex investment to meet load growth locally
- Cost-benefit analysis suggests payback period of less than 2-3.5 years based on OPEX model
- Incremental repair cost is lower by 50-60% than its equivalent new DT procurement cost with similar performance
- Creates an opportunity for the DT OEM or repairer to become a stakeholder in network O&M
- Controls the recurring losses by improved reliability of DTs


Thus, proposed Active Repair concept has the potential for improving the Energy Efficiency and reliable performance of Distribution Transformer.

3. Methodology

A step-by-step approach was adopted during the Repair execution to ensure checks & validation at each level (See below methodology)



4. Timelines



**Please Refer Annexure- 1 for MoU signed between TANGEDCO and ICAI*

5. Repair Execution for performance improvement of 100 KVA old DT

The Active Repair executed envisions to achieve lowest losses and kVA capacity enhancement of existing repaired DT sample. The focus is on reduction of full load losses (as most of DTs are reported to be loaded 80% and above) and thereby getting maximum possible efficiency, as well as the capability to perform under overloading conditions. Design of existing HV has been altered with use of copper, being mechanically and electrically superior, as winding material while LV winding material has been kept unchanged (i.e. Aluminium).

5.1.1. 'Baseline' measurement

The below table summarizes key baseline parameters, measured at NABL lab, of acquired failed 100kVA DT and its related details:

Parameters	Units	GTP Values	Test Value	% Deviation from GTP values
Capacity	kVA		100	-
Make			KEL	-
Year of Mfg.			2010	-
Sr. No.			64428	-
LV winding material			Al	-
HV winding material			Al	-
Total Winding Weight	kg		46.62	-
Impedance	%	5.06	4.40	-
No load loss	Watts	260	474.74	82% higher
Full load loss	Watts	1760	2067.60	17% higher
Total loss	Watts	2020	2542.00	26% higher

Table 1. Key Baseline Parameters of Distribution Transformer-100kVA

*Kerala Electrical and Allied Engg. Co. Ltd

5.1.2. Solution Design

Based upon the baseline measurements, design options for repairs was worked out initially. Thereafter, in consultation with TANGEDCO R&D team & design experts they were finalized as below:

Rating	Solution Design	Core unchanged	Designed LV winding (Material, ID, OD, Height)	Designed HV winding (Material, ID, OD, Height)	Estimated No load Loss as per design (Watts)	Estimated Full load Loss as per design (Watts)	Estimated Total Loss as per design (Watts)
100 kVA	LV Al & HV Cu (Reduced losses; increased kVA)	Yes	Al, 122, 163, 408	Copper, 183, 243, 383	474 (with existing core used)	1700	2174

Table 2. Design Solution finalized for ActiveRepair-100kVA

5.1.3. Active Repair Execution

5.1.3.1. Pre-repair testing

The execution process was undertaken with pre-repair testing of failed DT (see Annexure-2 for detailed Pre-repair test report) No-load loss value and full load loss value was measured. The testing was undertaken in presence of TANGEDCO representative as per IS 2026 at NABL lab. Some images are shown below:



Figure 1. Acquiring conventionally repaired DT



Figure 2. Dismantling and inspection of transformer




Figure 3. Pre-repair condition of coil



Figure 4. Pre-repair coil sectional view



Figure 5. NABL Pre-repair Testing with TANGEDCO representatives



Figure 6. TANGEDCO representative & team recording the data

5.1.3.2. Repair Activity

After pre-repair testing, the Active Repair was undertaken as per finalized designs. Sequence of repair activities which was undertaken reflecting best practice norms is as follows:

- Unstacking of core laminations and restacking them tightly to reduce air gap between laminations
- Procuring right kind of material for winding
- Providing oil flow duct while preparing winding sections
- Making LV and HV winding as per design specification and assembling
- Assembled transformer was moved for oven drying to remove moisture
- Eventually, oven dried transformer was placed in tank as final assembly

Some images during the process are shown below:



Figure 7. LV winding



Figure 8. HV winding



Figure 9. Core and coil assembly



Figure 10. Final repaired DT ready for post repair testing

5.1.3.3. Post Repair Testing

After repair, post repair testing was undertaken in presence of TANGEDCO representative as per IS 2026 (see Annexure-3 for detailed Post-repair test report) . Some images are shown below:



Figure 11. Setting up connections for testing



Figure 12. Post Repair testing and recording measurements

Active Repair for Performance Improvement of DTs for TANGEDCO



Figure 13. Post Repair Testing at NABL lab



Figure 14. Setting up connections for enhanced capacity testing at NABL



Figure 15. Testing at NABL on 13-12-2019 SE R&D with the team



Figure 16. Testing at NABL on 12-12-2019 CE R&D with the team



Figure 17. Testing for enhanced capacity testing at NABL



Figure 18. Final repaired DT ready for reconnecting in the network

After conducting all tests, results were obtained for various parameters in reference to the baseline measurements. Post-repair enhanced capacity testing was further validated by NABL by conducting loss, impedance measurement and Heat Run tests. The capacity enhancement of 8 kVA was noted. The transformer losses at enhanced capacity of 108 kVA was also measured and heat run test was conducted at this enhanced capacity (see annexure 3a post repair enhanced capacity test report). Following are the results obtained:

Key Design Parameters	Unit	Specification	Baseline (As-Is)	Post repair results (measured at NABL)	Post repair results measured at enhance kVA capacity at NABL
Capacity	kVA	100.00	100	100	108
Year of Manufacturing		-	2010	-	
Flux Density	Tesla	1.55	-	-	
LV Winding Material		-	DPC Al	DPC Al	DPC Al
HV Winding Material		-	DPC Al	DPC Cu	DPC Cu
No Load Loss	Watt	260	474	472	472
Full Load Loss	Watt	1760	2067	1559	1833
Total Loss	Watt	2020	2542	2035	2306
Impedance	%	5.00	4.40	4.54	4.64

Table 3. Comparative Pre and Post repair results

5.1.4. Post Repair reconnection of DT in the network

Post Repair and testing the DT was collected back from NABL lab. It is immediately connected back in the network at CEDC Chengalpet Electricity Distribution Circle and commissioned. Energy meter was also connected on LT side along with the DT erected in the pole.



Figure 19. Collecting Active Repaired DT from NABL lab



Figure 20. Removing existing DT for replacing it with Active Repaired DT



Figure 21. Connecting Active Repaired DT back into the DT at Chengalpet Electricity Distribution Circle



Figure 22. APFC Panel and Energy Meter connected at pole

5.1.5. Cost-Benefit Analysis

5.1.5.1. Top Results

Summary of Cost Benefit Analysis (CBA) is indicated below. The detailed CBA and assumptions are attached separately (*Please refer Annexure-4*).

Parameter		Unit	Value
Total Normal Repair cost (with Al winding)	A	Rs.	22,946
Labour and transportation cost		Rs.	2,700
Material cost (Rs. 304/kg for DPC Al/kg)		Rs.	20,246
Total Active Repair cost (HV-Cu, LV-Al)	B	Rs.	68,930
Labour and transportation cost		Rs.	2,700
Material cost (Rs. 304 for DPC Al/kg + Rs.635 for DPC Cu/kg)		Rs.	66,230
Incremental cost for To-Be Active Repair over and above Normal Repair	C=B-A	Rs.	45,983
Yearly units saved over baseline		kWh/year	2,198
Money saved in 10 years		Rs.	2,04,933
Payback period		years	3.20

Some key assumptions made for payback calculations:

1. DT loading – 70% (for urban area as per the TOC formula recommended by CEA)
2. Average Cost of Supply (ACoS) of 5.85 Rs. /kWh⁵
3. 10% CAGR assumed for Average Cost of Supply⁶
4. Normal As-Is repair cost for 100 kVA Al DT is INR 22,946 (as per base price of Discom)
5. Incremental repair cost over and above normal repair is used for payback calculation. (The labour rates for repair remain similar to that of Normal repair)

⁵ [TNERC Tariff Order 2017-18, Page no. 292](#)

⁶ This trend has been seen across Discoms from states (like Maharashtra, MP) and hence a normalized value of 10% is assumed

6. 70% term loan assumed with 9.93% rate of interest⁷

5.1.5.2. Scenario Analysis

A sensitivity analysis determines how different values of an independent variable affect a particular dependent variable under a given set of assumptions. In other words, sensitivity analysis study shows how various sources of uncertainty in a business economy model contribute to the model's overall uncertainty. For example, we have calculated the sensitivity of CAGR of Avg. Cost of Supply to payback period by changing the values of %CAGR while keeping all other values same.


Sensitivity to CAGR of Avg. Cost of Supply

Solution	Payback period (years)		
	For 0% CAGR	For 5% CAGR	For 10% CAGR
	3.58	3.37	3.20

Sensitivity to DTR Loading

As case for increasing DTR load, payback period will further reduce

Solution	Payback period (years)			
	70% DTR Load	80% DTR Load	90% DTR Load	100% DTR Load
	3.20	2.53	2.06	1.72



Sensitivity to increased kVA capacity

If an additional benefit of increased kVA capacity (**108 kVA from 100 kVA**) is considered, then payback will reduce further.

Solution	Payback period (years)	
	Increase in kVA capacity not considered	Considering Increase in kVA capacity
	3.20	2.19

⁷ Power Utilities operate with a debt equity ratio of 70:30 as per national tariff policy. Hence the 70% loan is considered.

Sensitivity to Salvage value of Cu at the end of service Life

The salvage value of Cu does not impact the payback but improves the Project IRR (Internal Rate of Return). Please refer Annexure-5 for detailed analysis of IRR

	Project IRR (%) without Cu Salvage value	Project IRR (%) with Cu Salvage value
@ACoS 5.85 Rs./kWh		
100kVA	44.42	45.81

6. Key Observations

Following are some key observations drawn from tests and cost benefit analysis:

1. Old DT has high technical losses with large deviation from spec values as seen from pre-repair testing:

No Load Loss	+82%
Full Load Loss	+17%
Total Loss	+26%

2. Repair does help in technical loss reduction (compared to baseline values). Total loss was reduced by 26% from the baseline.

3. Actual Repair results were close to the design estimations and even better than expected


	Assumed Designed values	Actual observed (at NABL)
For 100 kVA		
Total Loss (W)	2,174	2,035

4. Cost Benefit Analysis is as follows (Please refer Annexure-4)

Payback Period (Yrs.)	
Without kVA Enhancement	3.20
With kVA Enhancement	2.19

- 4.1. In additional sensitivity analysis carried out shows possible **1.72-2.19 years' payback period with capacity enhancement** (as seen in section 5.1.5.2) for real life assumptions, indicating high potential opportunity.
5. It is evident from the Post repair test results that, in addition to the increased efficiency the continuous loading ability/capacity of 100kVA Transformers is increased to 108kVA without affecting the Temperature Rise limits & Impedance Parameters as per IS 2026.
6. The design values and actual post-repair loss are fairly close and lower than the design. At 108 kVA the temperature rise values are lowered but the test value was marginally above the IS limits. Hence it can be inferred that DTs can have a baseline for technical losses at on-site. Thus, the close estimation of 'To-Be' loss levels and associated CBA can be undertaken. Further, business as usual repair practices do not address the issue of higher losses thus causing further deterioration in efficiency level post repair.

7. **Upgradation of old DTs:** Active Repair enhances the performance of the old DT to a level closer to Energy Efficiency Level-1 loss stipulated as per IS 1180 at 100% loading. The post active repair full load losses have been compared with full load loss computed at 100% loading (with reference to no-load loss computation done by PGVCL (Gujarat Discom)). *(Please refer Annexure-6 IS 1180 relevant efficiency page)*



7. Key Recommendations

1. **Modify existing in-house or contracted DT repair process:** DTs being repaired in-house should go through a process change to improve the repair practices. Some suggested changes are:
 - a. Pre-repair testing of DTs to be done to check the loss levels. This may not be feasible in failed DT except for no load loss assessment. It is recommended to carry out no load test at rated voltage with healthy LV/dummy LV turns to ensure that the no load losses do not exceed 1.5 times the original no load losses measured as per IS 2026 (Part 1). In case, if no load losses exceed 1.5 times the original no load losses, the transformer should be redesigned or transformer core to be scrapped. It is also recommended to measure the resistance of any one Healthy LV & HV Coil & calculation for estimation of approximate Full load Loss can be done thereof.
 - b. DTs to be opened to check for core/ winding damage
 - c. Design improvement option to be explored to enhance capacity and reliability of the DT
 - d. Winding replacement to be done by using standard material (preferably copper)
 - e. Provide adequate ducts in the windings, to ensure effective cooling and reduced temperature rise.
 - f. Post repair testing to be conducted to measure losses and at times temperature rise test to be conducted on sample active repaired DT to check capacity enhancement
 - g. On a sample basis, repaired DTs to be tested at NABL accredited lab
 - h. Internal painting should be mandatorily done to reduce the stray losses through tank
2. **Introduce performance-tied repair contract:** DTs being repaired by the vendors (outsourced) must be tied with its performance. A performance-tied repair contract needs to be drafted for improvement in the loss levels/kVA capacity of the DT. Under this contract, repairer will have to improve the DT

performance (i.e. losses) by certain percentage, which on achievement will gain incentives to repairer whereas underachievement will be liable to penalty.

3. **Strengthen Repair Standard Operating Procedure (SOP) for repair:** A standardized repair practice must be followed for efficient repair of DTs. Strengthening the SOP shall benefit the DISCOM in acquiring good quality repaired DTs, thereby increasing its operational life in the network. In addition, these repaired DTs shall perform equivalent to new procured DTs and help DISCOM in reducing procurement costs.
4. **Proactive preventive maintenance:** Continue implementation of periodic condition monitoring of DTs. This effort definitely helps Discom monitor the health of DTs for effective asset management.
5. **Monitor and control DT loading through remote metering** of DTs and selective APFC installation for mitigating re-active load on the DTs. Supervision with monitoring DTs' health on a continuous basis including periodic checks on the loads and load pattern will enhance their life and ensure continuous performance near to designed parameters.

8. Applicability to broader TANGEDCO Utility

1. TANGEDCO is the large power distribution company in India, catering State of Tamil Nadu, with total DTs count of 2,93,301. The AT&C losses is around 13.64% as per UDAY portal.
2. The above concept has been explored for sample DT only. However, depending on the condition of old DTs, some of them may have to be scrapped while some of them can be repaired under this concept.
3. Also, the concept involves costing which may be different for different manufacturers depending on the design specifications.
4. There can be other business models like incentivizing vendors to reduce NL and FL losses below ideal values, etc. with payback period ranging from 1-2.3 years.
5. Based on the estimation of loss deviations (based on the **assumptions** that legacy DTs at TANGEDCO currently have No-load loss deviation of 15% and full load loss deviation of 30%) of Discom data and representing at TANGEDCO level, it is observed that DTs contribute ~5.22% of technical losses at overall utility level, resulting into 2,257 Cr. loss (assuming avg. cost of power supply as 5.85 kWh/unit). *(Please refer Annexure-7)*

	Scenario 1 (if DTs perform as per specs)	Scenario 2 (if DTs are at acceptable loss levels)	Scenario 3 (if losses are high deviated from spec)	Scenario 4 (if DTs are Active Repaired with reduced losses)
%loading	70%	70%	70%	70%
%deviation of No-load loss	0%	15%	15%	10%
%deviation of Full load loss	0%	15%	30%	-30%
Estimated total losses (MUs/year)	3,391	3,730	3,859	2,696

Active Repair for Performance Improvement of DTs for TANGEDCO

% Total losses with respect to energy input	4.58%	5.04%	5.22%	3.65%
Total DT technical losses (Cr.)	1,983	2,182	2,257	1,577

Assumptions		
Total Transformers	#	2,93,301
Avg. Loading	%	70%
Avg. Cost of power supply	kWh/unit	5.85
Total revenue of TANGEDCO (as per ARR)	Cr.	43,686
Energy Input (as per ARR 2017-18)	MU/year	73,761

6. If 5.22% technical loss can be brought down to 3.6% (based on best performing utility's standard) through effective & DT repair & maintenance, it can save nearly INR 680 Cr. per year (approx. 1.5% of Avg. revenue)
- 6.1. Even if only 100 kVA DTs (assuming 1,10,000 DTs i.e. ~37% of the MVA capacity) are Active Repaired it can save nearly **~200 Cr./year**

- **Old conventionally-repaired DTs have potentially higher technical losses than being thought (i.e. ~5.22%) causing loss of INR 2,257 Cr. annually.**
- **Performance Based Repair has the potential to reduce the technical losses and upgrade the DTs performance equivalent to Energy Efficiency levels as specified by IS 2026. It can save nearly INR 680 Cr. per year (approx. 1.5% of Avg. revenue)**

Annexures

Annexure-1: MoU signed between TANGEDCO and ICAI



தமிழ்நாடு தமிலநாடு TAMILNADU
21-10-19 INTERNATIONAL COPPER ASSOCIATION
MUMBAI, INDIA. BV 872565
ச. கருமங்கலம் ராயன்,
மத்திய மரத்தாள் உற்பத்தியாளர்
உ. No: 2, / CGL / 2010
மாவட்டம் கட்டு ஏராளம்.

Memorandum of Understanding (MOU)

This MOU between Tamil Nadu Generation and Distribution Company Limited (TANGEDCO) Chennai and International Copper Association India (ICAI) Mumbai is to carry out study in improving energy efficiency, reliability and life cycle management of Distribution Transformers (DTs).

ICAI has shared one proposal for undertaking a proof of concept to demonstrate effectiveness and viability of active repair of legacy DTs. The scope of the study is enclosed herewith.

This MOU entrust both organizations to engage in knowledge in DT life cycle management.

For TANGEDCO
Chief Engineer/IC,R&D
Superintending Engineer/R&D
Executive Engineer/R&D
Date: 21.10.19

For ICAI
INTERNATIONAL COPPER ASSOCIATION INDIA
Manas Kundu
Designation: Director (Energy Solutions)
Date: 21st Oct'19

Active Repair for Performance Improvement of DTs for TANGEDCO

Proposal for Technical Loss Reduction & Reliability Improvement in Distribution Transformers via Active Repairs

Proof of Concept (PoC) study for TANGEDCO

Background

Power Distribution in India is facing multiple challenges - increasing power demands, increasing energy costs, higher operating costs, higher losses and rising consumer Tariffs. Loss reductions (both Technical and Commercial) become one critical intervention for course correction. Commercial loss reduction has taken utility's greater attention, particularly in respect of legacy assets in the system - one critical of them being Distribution Transformers.

Proof of Concept (PoC) Introduction:

With this background, International Copper Association India (ICAI) has developed a concept to reduce Technical Losses & Improve Reliability in Distribution Transformers via Active Repair approach. It intends to establish this new Business Model with a Proof of Concept (PoC) for TANGEDCO, and hence this proposal is evolved.

M/s ICAI has proposed a study on Reliability Improvement and Technical Loss Reduction via active repair experiment. The process of active repair involves the replacement of HV-Aluminium winding available in the 100kVA Distribution Transformer by a copper winding optimally designed for the same core. If needed, the LV winding would also be replaced with an optimally designed Aluminium winding to increase the capacity of the Transformer.

Objective of the PoC

- Validation of Technical loss performance of DT in two stages - pre and post Active Repair
- Calculation of savings generated in units of electricity due to reduction in technical losses vs. active repair solution and costs
- Calculation of possible enhancement in the capacity of the Transformer by extrapolation of results and then validating the enhancement by additional test result.

DTs Selection for PoC

- **Location:** One DT from Chenglepet circle of TANGEDCO is considered for active repair.
- **Identification of DT:** It shall be carried on 1 number DT of 11kV/433V, 100kVA capacity (Make: KEL; SI No: 64428; Year of Manufacturing: 2010).

PoC Roles & Responsibilities

- The suggested roles for the various agencies involved in this PoC implementation are enclosed in the Annexure.

Terms and Conditions

- **Funding** - This PoC phase shall be fully funded by ICAI. There will be no financial commitment for TANGEDCO.
- **Repair Warranty** - The DTs shall be covered with repair warranty terms and conditions for one year by ICAI. ICAI agrees to replace the copper HV winding with a Aluminium winding and bear the cost of repair, if the active repaired Transformer fails within the above warranty period.
- **Time for repairs** - Total repair time is estimated around 6-8 weeks.
- **Co-operation** - TANGEDCO Technical / Operations team will extend the required coordination for timely start and close of the PoC.
- **Selection of Repair vendor** - Active repair work on the identified Transformer shall be carried out by M/s ICAI at M/s. Sakthi Transformers, Plot No 10-11, Sharma Nagar, Kundrathur, Thiruneermalai Main Road, Chennai-69 at the cost of ICAI.
- **Pre and Post Repair testing** - The active repaired Transformer will be pre and post tested for No Load Loss, Load Loss @ 50%, 70% and 100%, Heat run at the NABL facility - M/s Shree Abirami Engineering Works, Pillaiappakkam, at the cost of ICAI.
- **Released Aluminium Winding** - During active repair, M/s ICAI shall handover the released windings of HV and LV (if replaced) of the Transformer to TANGEDCO.

For TANGEDCO

[Signature]
21/10/19
Chief Engineer/IC,R&D

[Signature]
21/10/19
Superintending Engineer/R&D

[Signature]
21/10/19
Executive Engineer/R&D

Date: 21.10.19

For ICAI

INTERNATIONAL COPPER ASSOCIATION INDIA

[Signature]
21/10
By: Manas Kundu

Designation: Director (Energy Solutions)
Date: 21st Oct '19

ANNEXURE - ACTIVITIES INVOLVED IN THE PoC STUDY

Sl No	Activity	Work done by	Expenditure to be met by
1	Transporting the Transformer to the repair factory	ICAI	ICAI
2	Confirming the healthiness of the Transformer at the repair factory by relevant tests	Repair factory	ICAI
3	Shifting the Transformer to a NABL Testing facility	ICAI	ICAI
4	Conducting the No Load Loss, Load Loss at 50%, 70%, 100% and Heat run test	NABL Facility	ICAI
5	Witnessing the Test at NABL Facility	ICAI, TANGEDCO (CEDC,R&D)	-
6	Shifting the Tranformer back to Repair Factory	ICAI	ICAI
7	Opening the Transformer and completing the active repair	Repair Factory	ICAI
8	Confirming the healthiness of the Transformer at the repair factory	Repair Factory	ICAI
9	Shifting the Transformer to a NABL Testing facility	ICAI	ICAI
10	Conducting the No Load Loss, Load Loss at 50%, 70%, 100% and Heat run test	NABL Facility	ICAI
11	Witnessing the Test at NABL Facility	ICAI, TANGEDCO (CEDC,R&D)	-
12	Ensuring the enhanced capacity of the Transformer by extra-pulation based on the test result	ICAI, TANGEDCO (CEDC,R&D)	-
13	Confirming the enhanced capacity by doing heat run test again.	NABL Facility	ICAI
14	Witnessing the Test at NABL Facility	ICAI, TANGEDCO (CEDC,R&D)	-
15	Shifting the Tranformer back to Chenglepet EDC and re-erection	ICAI	ICAI
16	Preparing the study report	ICAI, TANGEDCO (CEDC,R&D)	ICAI

CE/IC R&D
21/10/19

INTERNATIONAL COPPER ASSOCIATION INDIA

M. S. Jayaraman
21/10

21/10/19
TANGEDCO/Chennai

Active Repair for Performance Improvement of DTs for TANGEDCO

Annexure 2: Snapshot of Pre-Repair Test Report conducted at NABL


IMPULSE TEST LAB
(Where Advanced Engineering Works)
 Survey No: 22/1 & 22/2, Sriperumbudur A Village,
 Kodambakkam - Sriperumbudur High Road, SH 113,
 Near TVH Swaya Apartments, Sriperumbudur- 602 105.
 Phone No: 044-27176120 E-mail: 24001vtrl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
REPORT NO: SAEW/ITL/2019-20/N-005 **DATE: 01-11-2019**

TEST REPORT		
Name & Address of the Customer: International Copper Association India 302, Alpha, Hiranandani Business Park, Powai, Mumbai – 400076	Report No. : SAEW/ITL/2019-20/N-005 Date : 01-11-2019	Location of Testing: Impulse Test Lab
	Customer Ref No with date:	Date of Sample Receipt: 25-10-2019
	Condition of the sample at time of receipt: Good	Date(s) of Testing: 30 & 31-10-2019
Sample Description : Make: KEL Power Rating : 100KVA Voltage Rating : 11000V/ 433V Current Rating : 5.24A / 133.33A Detailed Description: In Sheet No. 2	Sample Identification: N-005 ITL Sample No : SAEW/ITL/2019-20/N-005 Manufacturer Serial No : 64428 Make : KEL Year Of Manufacture : 2010 Enclosed Drawing Numbers : NIL	
Test Details: In Sheet No. 3; Sample Technical Specification: In Sheet No. 2		
Test Results: Sheet No. 4 to Sheet No. 10		
Enclosure: Photographs of test samples – Sheet No.11 and Sheet No.12		
Remarks: <div style="text-align: center;">NIL</div>		
PREPARED BY CHECKED BY APPROVED BY (K CHANDRASEKAR)		
<small>NOTE: 1. This report only relates to the particular sample received for testing in good condition at ITL, Sriperumbudur. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from ITL. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Sriperumbudur will be the exclusive jurisdiction & shall be conducted at where the cause has arisen. Caution: ITL is not responsible for the authenticity of photocopied or reproduced test reports. ITL provides support to consumers for verification of the authenticity of test reports issued by ITL.</small>		

TECHNICAL SPECIFICATION OF TEST OBJECT ASSIGNED BY CUSTOMER	
1	Name Of the Manufacturer
2	Serial Number
3	Power Rating(kVA)
4	Rated Voltage H.V (Volts)
5	Rated Voltage L.V (Volts)
6	Rated Current H.V (Amps)
7	Rated Current L.V (Amps)
8	Number Of Phases
9	Energy Efficiency Level
10	Vector Group
11	Winding Material
12	Type Of Cooling
13	Frequency(Hz)
14	Guaranteed Percentage Impedance(3)
15	Guaranteed No Load Loss(Watts)
16	Guaranteed Load Loss at 75°C (Watts)
17	Total Loss at 50% Load (Watts)
18	Total Losses at 100% Load (Watts)
19	Guaranteed Temperature rise of Oil
20	Year of Manufacture
21	Standard No:
	Kerala Electrical and Allied Engg. Co. Ltd
	64428
	100
	11000
	433
	5.24
	133.33
	3
	-
	Dyn11
	Aluminum
	ONAN
	50
	5.06
	-
	-
	-
	-
	45°C
	2010
	IS 2026 / IEC 60076 / CBIP

Active Repair for Performance Improvement of DTs for TANGEDCO

1. MEASUREMENT OF WINDING RESISTANCE

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS:2026 (Part 1): 2011 (Clause 10.2)	SAEW/EQ/34	Transformer winding resistance meter (Prestige)	PE/040/569/2018
IEC 60076-1 (Edition 3.0) (2011-04) (Clause 11.2)	SAEW/EQ/05	Infrared Thermometer (Metric)	02979373

Top oil (°C)	28.0	Bottom oil (°C)	26.2	Average (°C)	27.1
--------------	------	-----------------	------	--------------	------

A) HV Winding

Tap No	Measured Values (Ω)			R _{avg} (Ω)	R _{avg} (Ω) (75° C)
	1U1V	1V1W	1W1U		
NA	24.86	24.38	24.46	24.566	29.233

B) LV Winding

Tap No	Measured Values (mΩ)			R _{avg} (mΩ)	R _{avg} (mΩ) (75° C)
	2u2n	2v2n	2w2n		
NA	11.89	12.00	12.27	12.053	14.343

Tap No	Measured Values (mΩ)			R _{avg} (mΩ)	R _{avg} (mΩ) (75° C)
	2u2v	2v2w	2w2u		
NA	23.65	23.78	23.90	23.78	28.298

3. MEASUREMENT OF SHORT CIRCUIT IMPEDANCE AND LOAD LOSS

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS:2026 (Part 1): 2011 (Clause 10.4)	SAEW/EQ/12	Digital Power Meter (Yokogawa)	C35H12030E
IEC 60076-1 (Edition 3.0) (2011-04) (Clause 11.4)	SAEW/EQ/06	Potential Transformer (Excel power)	R-633/18, V-634/18, B-635/18
CBIP Manual Pub.No.317/2013 Sec. 8B 3.1	SAEW/EQ/07a	Current Transformer (Kaipa)	R-133287/17, Y-133288/17, B-133289/17
	SAEW/EQ/05	Infrared Thermometer (Metric)	02979373

WINDING SHORTED	LV
WINDING SUPPLIED	HV
RATED KVA	100

Top oil (°C)	28.0	Bottom oil (°C)	26.2	Average (°C)	27.1
--------------	------	-----------------	------	--------------	------

Rated Voltage HV (kV)	11
Rated Voltage LV (kV)	0.433
Rated Current HV (A)	5.24
Rated Current LV (A)	133.33

MEASURING PARAMETERS:

Tap No	Average Current (A)	Average Voltage (line) (V)	Total Power (W)
NA	5.2351	484.08	1769

CALCULATING PARAMETERS:

Tap No	Current in Amps		Resistance at 75°C (mΩ)		I²R AT 75°C (W)		Total I²R AT 75°C (W)
	HV WDG	LV WDG	HV WDG	LV WDG	HV WDG	LV WDG	
NA	5.24	133.33	29233	14.343	1204	764.921	1968.921

Tap No	Impedance Voltage (V)	Corrected Power (W)	At Rated KVA (75°C)		% Impedance (% Z)
			Stray Losses (W)	Load Losses (W)	
NA	484	1772	98.697	2067.618	4.40

2. MEASUREMENT OF NO LOAD LOSS AND CURRENT

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS:2026 (Part 1): 2011 (Clause 10.5)	SAEW/EQ/12	Digital Power Meter (Yokogawa)	C35H12030E
IEC 60076-1 (Edition 3.0) (2011-04) (Clause 11.5)	SAEW/EQ/06	Potential Transformer (Excel power)	R-633/18, V-634/18, B-635/18
CBIP Manual Pub.No.317/2013 Sec. 8B 3.1	SAEW/EQ/07a	Current Transformer (Kaipa)	R-133287/17, Y-133288/17, B-133289/17

WINDING EXCITED	HV
WINDING OPENED	LV
HV RATED VOLTAGE (kV)	11
BASE KVA	100
TAP NO	NA
FREQUENCY (Hz)	50Hz

% VOLTAGE	APPLIED VOLTAGE (Line) (kV)	RMS CURRENT in Amps	NO LOAD LOSS IN W	
			Measured Loss	Corrected Loss
90	9.873	0.0879	325	325.888
100	11.006	0.1697	475	474.74
110	12.096	0.4548	746	746.246

4. TEMPERATURE RISE TEST

Test Standard	EQ ID	Equipment Used	Serial Number
IS:2026 (Part 1): 2011 (Clause 10.4)	SAEW/EQ/12	Digital Power Meter (Yokogawa)	C35H12030E
IEC 60076-1 (Edition 3.0) (2011-04) (Clause 11.4)	SAEW/EQ/06	Potential Transformer (Excel power)	R-633/18, V-634/18, B-635/18
CBIP Manual Pub.No.317/2013 Sec. 8B 3.1	SAEW/EQ/07a	Current Transformer (Kaipa)	R-133287/17, Y-133288/17, B-133289/17
	SAEW/EQ/05	Infrared Thermometer (Metric)	02979373
	SAEW/EQ/34	Transformer winding resistance meter (Prestige)	PE/040/569/2018

A) Total Losses Injection

$$\text{Total Loss feed} = \text{No Load Loss} + \text{Load Loss} = 474.4\text{W} + 2067.618\text{W} = 2542\text{W} = 2.542\text{kW}$$

Time	Average Voltage (V)	Average Current (A)	Average Power (kW)	Ambient Temp 1 (°C)	Ambient Temp 2 (°C)	Ambient Temp 3 (°C)	Average Temp. (1+2+3)/3 (°C)	Top oil Temp. (b) (°C)	Top oil Temp. raise (b-a) (°C)
12.30	335.28	6.270	2.543	26.1	26.1	26.0	26.07	28	1.93
13.30	325.83	5.979	2.549	26.1	26.0	26.3	26.13	38.9	12.27
14.30	321.66	5.890	2.547	26.5	26.7	27.0	26.73	49.7	22.97
15.30	320.00	5.825	2.547	27.3	27.6	28.1	27.67	57.5	29.83
16.30	319.76	5.796	2.542	27.0	26.7	28.1	27.27	63.1	35.83
17.30	318.73	5.753	2.536	26.8	26.8	28.1	27.23	67.2	39.97
18.30	316.69	5.715	2.536	26.3	26.2	27.7	26.73	69.6	42.87
19.30	316.90	5.7063	2.542	26.1	26.1	27.5	26.57	71.5	44.93
20.30	316.22	5.696	2.543	26.1	26.3	27.4	26.60	72.5	45.90
21.30	314.93	5.664	2.526	26.6	26.5	27.8	26.97	73.7	47.63
22.30	315.98	5.690	2.538	26.7	26.5	28.0	27.07	74.7	47.63

Measured temperatures at radiator: Top: 56.8°C, Bottom: 41.2°C

B) Rated current injection

22.30	291.15	5.246	2.164	26.7	26.5	28.0	27.07	74.7	47.63
22.45	291.09	5.248	2.162	26.8	26.6	28.0	27.13	75.4	48.27
23.00	290.65	5.2355	2.146	26.7	26.5	28.0	27.07	75.2	48.13
23.15	290.86	5.2360	2.144	26.8	26.5	28.0	27.10	74.9	47.80
23.30	292.21	5.261	2.163	26.8	26.5	28.0	27.10	74.6	47.50

Measured temperatures at radiator: Top: 55.7°C, Bottom: 41.2°C

**IMPULSE TEST LAB**

(Shree Ahirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kvtd@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

REPORT NO: SAEW/ITL/2019-20/N-005

DATE: 01-11-2019

3. MEASUREMENT OF SHORT CIRCUIT IMPEDANCE AND LOAD LOSS

TEST STANDARD	EQID	Name with Make	Serial Number
IS 2026 (Part 1): 2011 (Clause 10.4), IEC 60076-3 (Edition 3.0): 2011-04 (Clause 11.4), CBIP Manual Pub.No.317/2013 (Sec. BB 3.4)	SAEW/EQ/2/2	Digital Power Meter (Yokogawa)	C39412030E
	SAEW/EQ/06	Potential Transformer (Excel)	R-633/18, Y-634/18, B-635/18
	SAE W/EQ/07a	Current Transformer (Kalpa)	R-187708/17, Y-187709/17, B-187710/17
	SAEW/EQ/05	Infrared Thermometer (Metrix)	02979373

WINDING SHORTED	LV
WINDING SUPPLIED	HV
RATED KVA	100

Top oil (°C)	28.0	Bottom oil (°C)	26.2	Average (°C)	27.1
--------------	------	-----------------	------	--------------	------

Rated Voltage HV (kV)	11
Rated Voltage LV (kV)	0.433
Rated Current HV (A)	5.24
Rated Current LV (A)	133.33

MEASURING PARAMETERS:

Tap No	Average Current (A)	Average Voltage (line) (V)	Total Power (W)
NA	5.2351	484.08	1769

CALCULATING PARAMETERS:

Tap No	Current in Amps		Resistance at 75°C (mΩ)		I²R AT 75°C (W)		Total I²R AT 75°C (W)
	HV WDG	LV WDG	HV WDG	LV WDG	HV WDG	LV WDG	
NA	5.24	133.33	29233	14.343	1204	764.921	1968.921

Tap No	Impedance Voltage (V)	Corrected Power (W)	At Rated KVA (75°C)		% Impedance (% Z)
			Stray Losses (W)	Load Losses (W)	
NA	484	1772	98.697	2067.618	4.40

**IMPULSE TEST LAB**

(Shree Ahirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kvtd@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

REPORT NO: SAEW/ITL/2019-20/N-005

DATE: 01-11-2019

4. TEMPERATURE RISE TEST

Test Standard	EQID	Name with Make	Serial Number
IS 2026 (Part 2): 2010 IEC 60076-2: 2011 CBIP Manual Pub.no.317/2013, (Sect BB 3.8)	SAEW/EQ/12	Digital Power Meter (Yokogawa)	C39412030E
	SAEW/EQ/06	Potential Transformer (Excel)	R-633/18, Y-634/18, B-635/18
	SAEW/EQ/07a/b/c	Current Transformer (Kalpa)	R-187708/17, Y-187709/17, B-187710/17
	SAEW/EQ/05	Infrared Thermometer (Metrix)	02979373
	SAEW/EQ/34	Transformer winding resistance meter (Prestige)	PE/04Q/SEP/2018

A) Total Losses injection

$$\text{Total Loss feed} = \text{No Load Loss} + \text{Load Loss} = 474.4\text{W} + 2067.618\text{W} = 2542\text{W} = 2.542\text{kW}$$

Time	Average Voltage (V)	Average Current (A)	Average Power (kW)	Ambient Temp 1 (°C)	Ambient Temp 2 (°C)	Ambient Temp 3 (°C)	Average Temp. (1+2+3)/3 (°C)	Top oil Temp. (b) (°C)	Top oil Temp. raise (b-a) (°C)
12.30	335.28	6.270	2.543	26.1	26.1	26.0	26.07	28	1.93
13.30	325.83	5.979	2.549	26.1	26.0	26.3	26.13	38.9	12.27
14.30	321.66	5.890	2.547	26.5	26.7	27.0	26.73	49.7	22.97
15.30	320.60	5.825	2.547	27.3	27.6	28.1	27.67	57.5	29.83
16.30	319.76	5.796	2.542	27.0	26.7	28.1	27.27	63.1	35.83
17.30	318.73	5.753	2.536	26.8	26.8	28.1	27.23	67.2	39.97
18.30	316.69	5.715	2.536	26.3	26.2	27.7	26.73	69.6	42.87
19.30	316.90	5.7063	2.542	26.1	26.1	27.5	26.57	71.5	44.93
20.30	316.22	5.696	2.543	26.1	26.3	27.4	26.60	72.5	45.90
21.30	314.93	5.664	2.526	26.6	26.5	27.8	26.97	73.7	47.63
22.30	315.98	5.690	2.538	26.7	26.5	28.0	27.07	74.7	47.63

Measured temperatures at radiator:-Top: 56.8°C, Bottom: 41.2°C

B) Rated current injection

22.30	291.15	5.246	2.164	26.7	26.5	28.0	27.07	74.7	47.63
22.45	291.09	5.248	2.162	26.8	26.6	28.0	27.13	75.4	48.27
23.00	290.65	5.2355	2.146	26.7	26.5	28.0	27.07	75.2	48.13
23.15	290.86	5.2360	2.144	26.8	26.5	28.0	27.10	74.9	47.80
23.30	292.21	5.261	2.163	26.8	26.5	28.0	27.10	74.6	47.50

Measured temperatures at radiator:-Top: 55.7°C, Bottom: 41.2°C

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

REPORT NO: SAEW/ITL/2019-20/N-005

DATE: 01-11-2019

Winding Resistance Test


A) HV Side

Time	Resistance in Ω
120	30.48
135	30.45
150	30.42
165	30.39
180	30.36
195	30.33
210	30.30
225	30.27
240	30.25
255	30.22
270	30.19
285	30.17
300	30.14
315	30.12
330	30.09
345	30.07
360	30.04
375	30.02
390	30.00
405	29.98
420	29.95
435	29.93
450	29.91
465	29.89
480	29.87

B) LV Side

Time	Resistance in m Ω
120	29.93
135	29.93
150	29.92
165	29.9
180	29.87
195	29.85
210	29.82
225	29.8
240	29.79
255	29.77
270	29.75
285	29.72
300	29.7
315	29.69
330	29.67
345	29.65
360	29.64
375	29.65
390	29.63
405	29.63
420	29.62
435	29.6
450	29.59
465	29.58
480	29.56

Top Oil Rise



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

REPORT NO: SAEW/ITL/2019-20/N-005

DATE: 01-11-2019

CALCULATIONS


Drop in average oil temp after reducing to rated current

at Steady state with rated loss
Top oil temp rise = 47.63° C
Ave oil temp rise = Top Oil rise - [Rad Gradient/2]
= 39.83° C

at Shut down with rated current
Top oil temp rise = 47.50° C
Ave oil temp rise = Top Oil rise - [Rad Gradient/2]
= 40.25° C

Drop in average oil temp after reducing to rated current = 0.42° C

HV Winding Rise



Corrected HV Winding temp rise with rated load = HV Winding temp rise with rated current + drop
In average oil temp after one hour with rated current

$$= 63.379 + 0.42$$

$$= 63.80^{\circ} \text{C}$$

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.


Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

REPORT NO: SAEW/ITL/2019-20/N-005

DATE: 01-11-2019

LV Winding Rise



Corrected LV Winding temp rise with rated load = LV Winding temp rise with rated current + drop
In average oil temp after one hour with rated current

$$= 67.64 + 0.42$$

$$= 68.06^{\circ}\text{C}$$

Result:

	Measured	Guaranteed
Top Oil Temperature Rise ($^{\circ}\text{C}$)	47.63	45
HV Winding Temperature ($^{\circ}\text{C}$)	63.80	-
LV Winding Temperature ($^{\circ}\text{C}$)	68.06	-



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.


Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

REPORT NO: SAEW/ITL/2019-20/N-005

DATE: 01-11-2019

PHOTOGRAPHS



Annexure 3: Snapshot of Post Repair test report conducted at NABL for 100 kVA DT



SAEW

IMPULSE TEST LAB
(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC76081900000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608
DATE: 13-12-2019

TEST REPORT

Name & Address of the Customer: INTERNATIONAL COPPER ASSOCIATION INDIA UNIT 1401-03, WING A, KAILASH BUSINESS PARK, PARKSITE, VIKHROLI, MUMBAI-400079	Report No. : SAEW/ITL/2019-20/N-010 Date : 13-12-2019	Location of Testing: Impulse Test Lab
	Customer Ref No with date: DT/ICAI/TANGEDCO/NABL/ 19-20 dated 22-10-2019	Date of Sample Receipt: 10-12-2019
	Condition of the sample at time of receipt: Good	Date(s) of Testing: 12 & 13-12-2019
Sample Description : Make: KEL Power Rating : 100kVA Voltage Rating : 11000V/ 433V Current Rating : 5.24A / 133.33A Detailed Description: In Sheet No. 2	Sample Identification: ITL Sample No : N-010 Manufacturer Serial No : 64428 Make : KEL Year Of Manufacture : 2010 Enclosed Drawing Numbers : NIL	
Test Details: In Sheet No. 3		Sample Technical Specification: In Sheet No. 2
Test Results: Sheet No. 4 to Sheet No. 10		
Enclosure: Photographs of test samples – Sheet No.11 and Sheet No.12		
Remarks: NIL	Details of the Witnessing Officer <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  Er.M.Chandran EE/R&D CHENNAI </div> <div style="text-align: center;">  Er.R.Usha AEE/R&D CHENNAI </div> <div style="text-align: center;">  Er.N.Sarathy Asst. Maintenance BENGALPATTU </div> <div style="text-align: center;">  Er.S.Baskar ICAI </div> </div>	
 PREPARED BY	 CHECKED BY	 APPROVED BY (R DHILIPKUMAR)
NOTE: 1. This report only relates to the particular sample received for testing in good condition at ITL, Sriperumbudur. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from ITL. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Sriperumbudur will be the exclusive jurisdiction & shall be constructed as where the cause has arisen. Caution: ITL is not responsible for the authenticity of photocopied or reproduced test reports. ITL provides support to consumers for verification of the authenticity of test reports issued by ITL.		

Active Repair for Performance Improvement of DTs for TANGEDCO




IMPULSE TEST LAB

(Shree Ahirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608
DATE: 13-12-2019

LV Winding Rise



Cold Resistance measured: 1U1V = 23.60 ohms (R cold) @ 29.1°C
Hot Resistance observed at shut down (from graph) = 27.933 ohms (R hot)
LV Winding ave temp rise with RATED CURRENT = $\frac{R_{hot} \times [225 + 29.1] - [225 + 29.53]}{R_{cold}}$
= 46.22°C

To correct the winding temperature to rated load condition

Corrected LV WINDING temp rise = 46.22 + 1.22 = 47.44°C

Result:

	Measured	Guaranteed
Top Oil Temperature Rise (°C)	38.37	45
HV Winding Temperature (°C)	46.02	55
LV Winding Temperature (°C)	47.44	55

PREPARED BY



CHECKED BY

Sheet No. 10 of 12



IMPULSE TEST LAB

(Shree Ahirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608
DATE: 13-12-2019

CALCULATIONS


Drop in average oil temp after reducing to rated current

at Steady state with rated loss
Top oil temp rise = 38.37°C
Ave oil temp rise = [Rad Gradient/2] = 30.07°C

at Shut down with rated current
Top oil temp rise = 36.6°C
Ave oil temp rise = [Rad Gradient/2] = 28.85°C

Drop in average oil temp after reducing to rated current = 1.22°C

HV Winding Rise



Cold Resistance measured: 1U1V = 15.504 ohms (R cold)
Hot Resistance observed at shut down (from graph) = 18.159 ohms (R hot)
HV Winding ave temp rise with RATED CURRENT = $\frac{R_{hot} \times [235 + 29.1] - [235 + 29.53]}{R_{cold}}$
= 44.80°C

To correct the winding temperature to rated load condition

Corrected HV WINDING temp rise = 44.80 + 1.22 = 46.02°C

PREPARED BY



CHECKED BY

Sheet No. 9 of 12

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608

DATE: 13-12-2019

Winding Resistance Test


A) HV Side(1V-1W)

Time	Resistance in Ω
90	18.097
105	18.087
120	18.077
135	18.067
150	18.058
165	18.047
180	18.038
195	18.03
210	18.021
225	18.013
240	18.007
255	17.997
270	17.99
285	17.982
300	17.972
315	17.966
330	17.958
345	17.952
360	17.945
375	17.937
390	17.930
405	17.925
420	17.918
435	17.913
450	17.905

B) LV Side(2v-2w)

Time	Resistance in m Ω
90	27.76
105	27.73
120	27.70
135	27.67
150	27.64
165	27.62
180	27.6
195	27.57
210	27.55
225	27.53
240	27.51
255	27.5
270	27.47
285	27.46
300	27.44
315	27.42
330	27.4
345	27.38
360	27.37
375	27.35
390	27.34
405	27.33
420	27.32
435	27.30
450	27.29

Top Oil Rise



PREPARED BY



CHECKED BY

Sheet No. 8 of 12



IMPULSE TEST LAB

(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608

DATE: 13-12-2019

4. TEMPERATURE RISE TEST

Test Standard	EQ ID	Equipment Used	Serial Number
IS 2026(Part 2): 2010	SAEW/EQ/12	Digital Power Meter (Yokogawa)	C35H12020E
IEC 60076-2 : 2011	SAEW/EQ/06	Potential Transformer(Luxel)	R-633/18, Y-634/18, B-635/18
CBIP Manual	SAEW/EQ/07a, 07b, 07c	Current Transformer (Kajco)	R-133287/17 Y-133288/17 B-133289/17
Pub.no.317/2013, (Sect BB 3.8)	SAEW/EQ/05	Infrared Thermometer(Metrolab)	G2979373
	SAEW/EQ/24	Transformer winding resistance meter (Prestige)	PE/040/SEP/2018
	SAEW/EQ/22	Data logger with sensor	K8179A2001014

A) Total Losses Injection

Total Loss feed = No Load Loss + Load Loss = 472.760W + 1562.217W = 2034.977W-2.035kW

Time	Average Voltage (V)	Average Current (A)	Average Power (kW)	Ambient Temp 1 (°C)	Ambient Temp 2 (°C)	Ambient Temp 3 (°C)	Average Temp. (1+2+3)/3 (a) (°C)	Top oil Temp. (b) (°C)	Top oil Temp. raise (b-a) (°C)
23.00	332.55	6.3807	2.034	25.5	25.5	26.0	25.6	27.6	1.54
00.00	324.41	6.1773	2.028	25.4	25.5	25.8	25.56	35.4	9.84
01.00	324.12	6.1627	2.031	25.2	25.3	25.7	25.4	43.3	17.9
02.00	321.80	6.1068	2.031	26.3	25.4	25.8	25.83	49.4	23.57
03.00	319.99	6.4960	2.029	26.6	25.8	26.1	26.16	54.1	27.93
04.00	319.71	6.0294	2.030	26.7	25.8	26.1	26.2	57.6	31.24
05.00	315.23	6.0191	2.030	26.7	25.9	26.1	26.23	60.4	34.17
06.00	320.96	6.0701	2.045	26.4	25.7	25.9	26	61.9	35.90
07.00	318.61	6.0412	2.070	26.4	25.7	25.9	26	62.9	36.90
08.00	316.98	5.9829	2.039	26.9	26.0	26.3	26.4	64.0	37.6
09.00	316.81	5.9889	2.048	27.4	26.9	27.0	27.1	64.8	37.7
10.00	315.17	5.9535	2.035	29.1	28.1	28.7	28.63	66.6	37.97
11.00	316.59	5.9646	2.045	29.4	28.5	29.2	29.03	67.4	38.37


Measured temperatures at radiator:-Top: 56.9°C, Bottom: 40.3°C

B) Rated current Injection

Time	Average Voltage (V)	Average Current (A)	Average Power (kW)	Ambient Temp 1 (°C)	Ambient Temp 2 (°C)	Ambient Temp 3 (°C)	Average Temp. (1+2+3)/3 (a) (°C)	Top oil Temp. (b) (°C)	Top oil Temp. raise (b-a) (°C)
11.02	278.04	5.2418	1.579	29.4	28.5	29.2	29.03	67.4	38.37
12.05	277.32	5.2438	1.564	30.0	28.9	29.3	29.53	66.1	36.6

Measured temperatures at radiator:-Top: 56.5°C, Bottom: 41.0°C

PREPARED BY



CHECKED BY

Sheet No. 7 of 12

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Ahirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608

DATE: 13-12-2019

3. MEASUREMENT OF SHORT CIRCUIT IMPEDANCE AND LOAD LOSS

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS 2026(Part 1): 2011 (Clause 10.4), IEC 60076-1(Edition 3.0) (2011-04) (Clause 11.4), CIRP Manual Pub.No.317/2013 (Sec. 8B 3.4)	SAEW/TQ/12	Digital Power Meter (Yokogawa)	C35H12030E
	SAEW/TQ/06	Potential Transformer (Excel)	R-633/18, Y-634/18, B-635/18
	SAEW/TQ/07a/07b/07c	Current Transformer (Kalpa)	R-133287/17 Y-133288/17 B-133289/17
	SAEW/TQ/05	Infrared Thermometer (Metrix)	02970373

WINDING SHORTED	LV
WINDING SUPPLIED	HV
RATED KVA	100

Temp:-29.1°C

Rated Voltage HV (kV)	11
Rated Voltage LV (kV)	0.433
Rated Current HV (A)	5.24
Rated Current LV (A)	133.33

MEASURING PARAMETERS:

Tap No	% Current Applied	Average Current (A)	Average Voltage(line) (V)	Total Power (W)
NA	50	2.6289	235.97	337.00
NA	70	3.6788	330.90	661.10
NA	100	5.2449	472.44	1351

CALCULATING PARAMETERS:

Tap No	Current in Amps		Resistance at 75°C (mΩ)		I²R AT 75°C (W)		Total I²R AT 75°C (W)
	HV WDG	LV WDG	HV WDG	LV WDG	HV WDG	LV WDG	
NA	5.24	133.33	18196	14.002	749.435	746.754	1496.189

Tap No	Impedance Voltage(V)	Corrected Power(W)	At Rated KVA (75°C)		%Impedance (% Z)
			Stray Losses (W)	Load Losses (W)	
NA	499.4	1348.477	66.028	1559.045	4.54

PREPARED BY: *Sandeep Thiyagarajan*
CHECKED BY: *M. S. Senthil*

Sheet No. 6 of 12



IMPULSE TEST LAB

(Shree Ahirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000016F
REPORT NO: SAEW/ITL/2019-20/N-010



Certificate No: TC-7608

DATE: 13-12-2019

2. MEASUREMENT OF NO LOAD LOSS AND CURRENT

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS 2026(Part 1): 2011 (CI no. 10.5) IEC 60076-1(Edition 3.0) (2011-04) (CI no 11.5) CIRP Manual Pub.No.317/2013(Sec. 8B 3.3)	SAEW/TQ/12	Digital Power Meter (Yokogawa)	C35H12030E
	SAEW/TQ/06	Potential Transformer (Excel power)	R-633/18, Y-634/18, B-635/18
	SAEW/TQ/07a/07b/07c	Current Transformer (Kalpa)	R-133287/17 Y-133288/17 B-133289/17

WINDING EXCITED	HV
WINDING OPENED	LV
HV RATED VOLTAGE (kV)	11
BASE KVA	100
TAP NO	NA
FREQUENCY (Hz)	50Hz

APPLIED ON HV SIDE

%Voltage	90%	100%	110%
Average Line Voltage (kV)	9.9027	11.0053	12.0885
Average Phase Voltage (kV)	5.7175	6.3541	6.9795
Average Current (A)	0.0948	0.1926	0.5820
Measured Loss (kW)	0.330	0.473	0.743
Corrected Loss (kW)	0.3299	0.4727	0.7437
Frequency (HZ)	50.103	49.992	49.956

PREPARED BY: *Sandeep Thiyagarajan*
CHECKED BY: *M. S. Senthil*

Sheet No. 5 of 12

Annexure 3.a: Snapshot of Post Repair test report conducted at NABL for enhanced kVA capacity (108 kVA)

**IMPULSE TEST LAB**

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kviti@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ULR NO: TC760819000000017F

REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

TEST REPORT

Name & Address of the Customer: INTERNATIONAL COPPER ASSOCIATION INDIA UNIT 1401-03, WING A, KAILASH BUSINESS PARK, PARKSITE, VIKHROLI, MUMBAI-400079	Report No. : SAEW/ITL/2019-20/N-011	Location of Testing: Impulse Test Lab
	Date : 18-12-2019	
	Customer Ref No with date: ICAI/2019-20/0034 dated 16-12-2019	Date of Sample Receipt: 10-12-2019
	Condition of the sample at time of receipt: Good	Date(s) of Testing: 17 & 18-12-2019
Sample Description : Make: KEL Power Rating : 108kVA Voltage Rating : 11000V/ 433V Current Rating : 5.66A / 143.99A Detailed Description: In Sheet No. 2	Sample Identification: ITL Sample No : N-011 Manufacturer Serial No : 64428 Make : KEL Year Of Manufacture : 2010 Enclosed Drawing Numbers : NIL	
Test Details: In Sheet No. 3		Sample Technical Specification: In Sheet No. 2
Test Results: Sheet No. 4 to Sheet No. 10		
Enclosure: Photographs of test samples – Sheet No.11		
Remarks: NIL	Details of the Witnessing Officer.	
	 Er.M.Chandran EE/R&D CHENNAI	 Er.R.Usha AEE/R&D CHENNAI
 Er.S.Baskar ICAI		
 PREPARED BY	 CHECKED BY	 APPROVED BY (R.DHILIPKUMAR)
NOTE: 1. This report only relates to the particular sample received for testing in good condition at ITL, Sriperumbudur. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from ITL. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Sriperumbudur will be the exclusive jurisdiction where the cause has arisen.		
Caution: ITL is not responsible for the authenticity of photocopied or reproduced test reports. ITL provides support to consumers for verification of the authenticity of test reports issued by ITL.		

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ULR NO: TC760819000000017F

REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

1. MEASUREMENT OF WINDING RESISTANCE

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS 2026 (Part 1): 2011 (Clause 10.2)	SAEW/EQ/34	Transformer winding resistance meter (Prestige)	PE/040/SEP/2018
IEC 60076-1 (Edition 3.0) (2011-04) (Clause 11.2)	SAEW/EQ/05	Infrared Thermometer (Metrix)	Q2979375

Temp-27.9°C

A) HV Winding

Tap No	Measured Values (Ω)			R _{avg} (Ω)	R _{avg} (Ω) (75° C)
	1U1V	1V1W	1W1U		
NA	15.450	15.433	15.415	15.432	18.196

B) LV Winding

Tap No	Measured Values (mΩ)			R _{avg} (mΩ)	R _{avg} (mΩ) (75° C)
	2u2n	2v2n	2w2n		
NA	11.86	11.79	11.75	11.8	13.998

Tap No	Measured Values (mΩ)			R _{avg} (mΩ)	R _{avg} (mΩ) (75° C)
	2u2v	2v2w	2w2u		
NA	23.57	23.46	23.47	23.5	27.877

PREPARED BY *Sandeep H*

 CHECKED BY *HSDW*
 Sheet No. 4 of 11



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ULR NO: TC760819000000017F

REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

2. MEASUREMENT OF NO LOAD LOSS AND CURRENT

TEST STANDARD	EQ ID	Equipment Used	Serial Number
IS 2026 (Part 1): 2011 (Clause 10.5)	SAEW/EQ/12	Digital Power Meter (Yokogawa)	C35M120308
IEC 60076-1 (Edition 3.0) (2011-04) (Clause 11.5)	SAEW/EQ/06	Potential Transformer (Excel power)	R-633/2B, Y-634/2B, B-635/2B
CBIP Manual Pub No. 317/2013 (Sec. 8B 3.3)	SAEW/EQ/07a	Current Transformer (Kalpa)	R-133287/17 Y-133288/17 B-133289/17

WINDING EXCITED	HV
WINDING OPENED	LV
HV RATED VOLTAGE (kV)	11
BASE KVA	108
TAP NO	NA
FREQUENCY (Hz)	50Hz

APPLIED ON HV SIDE

%Voltage	90%	100%	110%
Average Line Voltage (kV)	9.9027	11.0053	12.0885
Average Phase Voltage (kV)	5.7175	6.3541	6.9795
Average Current (A)	0.0948	0.1926	0.5820
Measured Loss (kW)	0.330	0.473	0.743
Corrected Loss (kW)	0.3299	0.4727	0.7437
Frequency (HZ)	50.103	49.992	49.956

PREPARED BY *Sandeep H*

 CHECKED BY *HSDW*
 Sheet No. 5 of 11

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000017F

REPORT NO: SAEW/ITL/2019-20/N-011

DATE: 18-12-2019



Certificate No: TC-7608

3. MEASUREMENT OF SHORT CIRCUIT IMPEDANCE AND LOAD LOSS

TEST STANDARD	EQ ID	Name with Make	Serial Number
IS 2026(Part 1): 2011 (Clause 10.4), IEC 60076-1 (Edition 3.0): 2011-04, (Clause 11.4), CIBP Manual Pub.No.317/2013 (Sec. 8B 3.4)	SAEW/TQ/12	Digital Power Meter (Yokogawa)	C35H12030E
	SAEW/TQ/06	Potential Transformer(Excel)	R-633/18, Y-634/18, B-635/18
	SAEW/TQ/07a/07b/07c	Current Transformer (Kajal)	R-133287/17 Y-133288/17 B-133289/17
	SAEW/TQ/05	Infrared Thermometer (Metrix)	02979373

WINDING SHORTED	LV
WINDING SUPPLIED	HV
RATED KVA	108

Temp-27.9°C	
Rated Voltage HV (kV)	11
Rated Voltage LV (kV)	0.433
Rated Current HV (A)	5.66
Rated Current LV (A)	143.99

MEASURING PARAMETERS:

Tap No	% Current Applied	Average Current (A)	Average Voltage(line) (V)	Total Power (W)
NA	50	2.8371	255.366	398.4
NA	70	3.9691	357.641	780.6
NA	100	5.6556	510.109	1577

CALCULATING PARAMETERS:

Tap No	Current in Amps		Resistance at 75°C (mΩ)		I²R AT 75°C (W)		Total I²R AT 75°C (W)
	HV WDG	LV WDG	HV WDG	LV WDG	HV WDG	LV WDG	
NA	5.66	143.99	18196	13.998	874.414	870.642	1745.056

Tap No	Impedance Voltage(V)	Corrected Power(W)	At Rated KVA (75°C)		%Impedance (% Z)
			Stray Losses (W)	Load Losses (W)	
NA	510.40	1579.455	88.149	1833.205	4.64

PREPARED BY: *Shree Abirami Engineering Works*

CHECKED BY: *MSA*

Sheet No. 6 of 11



IMPULSE TEST LAB

(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000017F

REPORT NO: SAEW/ITL/2019-20/N-011

DATE: 18-12-2019



Sharing Screenshot

A link to your screenshot was copied to your clipboard.



Certificate No: TC-7608

4. TEMPERATURE RISE TEST

Test Standard	EQ ID	Name with Make	Serial Number
IS 2026(Part 2): 2011 IEC 60076-2: 2011 CIBP Manual Pub.No.317/2013, (Sect 8B 3.8)	SAEW/TQ/12	Digital Power Meter (Yokogawa)	C35H12030E
	SAEW/TQ/06	Potential Transformer(Excel)	R-633/18, Y-634/18, B-635/18
	SAEW/TQ/07a/07b/07c	Current Transformer (Kajal)	R-133287/17 Y-133288/17 B-133289/17
	SAEW/TQ/05	Infrared Thermometer(Metrix)	02979373
	SAEW/TQ/34	Transformer winding resistance meter (Prestige)	PE/040/SAF/2018
	SAEW/TQ/22	Data logger with sensor	K8179A2001014

A) Total Losses Injection

Total Loss feed = No Load Loss + Load Loss = 472.760W + 1833.205W = 2305.965W=2.036kW

Time	Average Voltage (V)	Average Current (A)	Average Power (kW)	Ambient Temp 1 (°C)	Ambient Temp 2 (°C)	Ambient Temp 3 (°C)	Average Temp. (1+2+3)/3 (°C)	Top oil Temp. (b) (°C)	Top oil Temp. raise (b-a) (°C)
23.00	354.80	6.5375	2.303	25.7	25.6	25.7	25.66	25.5	-
00.00	345.18	6.5052	2.303	24.8	25.4	25.4	25.20	35.0	9.8
01.00	341.44	6.4785	2.303	26.1	25.4	25.8	25.76	42.5	16.74
02.00	340.12	6.4562	2.301	26.3	25.5	26.0	25.93	49.1	23.17
03.00	338.71	6.4102	2.308	26.5	25.6	26.0	26.03	54.2	28.17
04.00	337.30	6.3719	2.305	26.4	25.6	26.0	26.00	57.9	31.9
05.00	336.32	6.3479	2.306	26.3	25.4	25.8	25.80	62.9	37.10
06.00	335.61	6.3248	2.303	26.2	25.4	25.8	25.80	62.9	37.10
07.00	333.93	6.3137	2.305	26.3	25.4	25.9	25.86	64.4	38.54
08.00	334.27	6.3048	2.308	27.0	26.0	26.1	26.36	64.9	38.54
09.00	333.64	6.2883	2.306	28.1	26.7	27.6	27.46	65.7	38.24
10.00	331.72	6.2770	2.309	30.0	28.5	30.2	29.56	68.0	38.44
11.00	332.92	6.2645	2.306	30.3	29.1	31.4	30.27	68.6	38.33

Measured temperatures at radiator:-Top: 58.3°C, Bottom: 40.9°C

B) Rated current injection

11.01	301.77	5.6779	1.894	30.3	29.1	31.4	30.27	68.6	38.33
12.00	300.62	5.6676	1.873	30.6	29.4	31.6	30.53	62.7	32.17

Measured temperatures at radiator:-Top: 58.1°C, Bottom: 41.0°C

PREPARED BY: *Shree Abirami Engineering Works*

CHECKED BY: *MSA*

Sheet No. 7 of 11

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000017F
REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

Winding Resistance Test


A) HV Side(1V-1W)

Time	Resistance in Ω
75	18.406
90	18.393
105	18.38
120	18.368
135	18.357
150	18.347
165	18.335
180	18.325
195	18.313
210	18.304
225	18.295
240	18.285
255	18.274
270	18.265
285	18.257
300	18.247
315	18.24
330	18.229
345	18.223
360	18.215
375	18.206
390	18.198
405	18.189
420	18.184
435	18.176

B) LV Side(2V-2W)

Time	Resistance in m Ω
75	28.06
90	27.97
105	27.89
120	27.83
135	27.76
150	27.72
165	27.67
180	27.63
195	27.59
210	27.55
225	27.53
240	27.49
255	27.47
270	27.45
285	27.43
300	27.41
315	27.38
330	27.35
345	27.33
360	27.31
375	27.29
390	27.27
405	27.26
420	27.25
435	27.22

Top Oil Rise



PREPARED BY: *[Signature]*
CHECKED BY: *[Signature]*
Sheet No. 8 of 11



IMPULSE TEST LAB

(Shree Abirami Engineering Works)
Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.
Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ULR NO: TC760819000000017F
REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

CALCULATIONS


Drop in average oil temp after reducing to rated current

at Steady state with rated loss
Top oil temp rise = 38.33° C
Ave oil temp rise = Top Oil rise - [Rad Gradient/2]
= 29.63° C

at Shut down with rated current
Top oil temp rise = 32.17° C
Ave oil temp rise = Top Oil rise - [Rad Gradient/2]
= 23.62° C

Drop in average oil temp after reducing to rated current = 6.01° C

HV Winding Rise



Cold Resistance measured: 1U1V = 15.433 ohms (R cold)@27.9°C
Hot Resistance observed at shut down (from graph) = 18.468 ohms (R hot)
HV Winding ave temp rise with RATED CURRENT = $\frac{R_{hot} \times [235 + 27.9] - [235 + 30.53]}{R_{cold}}$
= 49.07° C

To correct the winding temperature to rated load condition

Corrected HV WINDING temp rise = 49.07 + 6.01 = 55.08° C

PREPARED BY: *[Signature]*
CHECKED BY: *[Signature]*
Sheet No. 9 of 11

Active Repair for Performance Improvement of DTs for TANGEDCO



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ULR NO: TC760819000000017F


REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

LV Winding Rise



Cold Resistance measured: 1U1V

= 23.46 ohms (R cold) @27.9°C

Hot Resistance observed at shut down (from graph) = 28.330 ohms (R hot)

HV Winding ave temp rise with RATED CURRENT

$R_{hot} \times [225 + 27.9] - [225 + 30.53]$

R_{cold}

= 49.87°C

To correct the winding temperature to rated load condition

Corrected LV WINDING temp rise = 49.87 + 6.01 = 55.88°C

Result:

	Measured	Guaranteed
Top Oil Temperature Rise (°C)	38.33	45
HV Winding Temperature (°C)	55.08	55
LV Winding Temperature (°C)	55.88	55

PREPARED BY



CHECKED BY

Sheet No. 10 of 11



IMPULSE TEST LAB

(Shree Abirami Engineering Works)

Survey No: 22/1 & 22/2, Sriperumbudur A Village,
Kodambakkam - Sriperumbudur High Road, SH 113,
Near TVH Svaya Apartments, Sriperumbudur- 602 105.

Phone No: 044-27176120 E-mail: 2400kvitl@gmail.com

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ULR NO: TC760819000000017F


REPORT NO: SAEW/ITL/2019-20/N-011



Certificate No: TC-7608

DATE: 18-12-2019

PHOTOGRAPHS



PREPARED BY



CHECKED BY

Sheet No. 11 of 11

Annexure-4: Cost Benefit Analysis

Key Design Parameters	Unit	GTP Values	As-Is (Baseline)	Actual (as per NABL)	Calculation for enhanced kVA	% Change from baseline
Capacity	kVA	100.00	100.00	100.00	108.00	0%
Year of Manufacturing		-	2013	-	-	
Flux Density	Tesla	-	1.55	-	-	
LV Winding Material		-	DPC Al	DPC Al	DPC Al	
HV Winding Material		-	DPC Al	DPC Copper	DPC Copper	
No Load Loss	Watts	260.00	474.00	472.00	473.00	0%
Full Load Loss	Watts	1,760.00	2,067.00	1,559.00	1,833.00	-25%
Total Loss @100% loading	Watts	2,020.00	2,541.00	2,035.00	2,306.00	1%
LV Winding Weight			24.00	23.08	23.08	
HV Winding Weight			42.60	93.25	93.25	
Total Winding Weight	kg		66.60	116.33	116.33	
% No Load Loss Deviation from GTP values	%	-	82%	82%		
% Full Load Loss Deviation from GTP Values	%	-	26%	1%		
% Total Loss Deviation from GTP values	%	-	26%	1%		

Losses and Savings Calculations												
5	Unit	As-Is		Actual (as per NABL)		Savings (as per NABL)						
Lost units from Technical Losses	kWh/year	13,024.63		10,826.57		2,198.06						
		Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10	Total
		1	2	3	4	5	6	7	8	9	10	
Units saved	kWh	2,198.06	2,198.06	2,198.06	2,198.06	2,198.06	2,198.06	2,198.06	2,198.06	2,198.06	2,198.06	21,980.59
Avg. Cost of Supply	INR/kWh	5.85	6.44	7.08	7.79	8.56	9.42	10.36	11.40	12.54	13.79	
Money saved	INR/year	12,858.65	14,144.51	15,558.96	17,114.86	18,826.34	20,708.98	22,779.88	25,057.86	27,563.65	30,320.02	2,04,933.71

Active Repair for Performance Improvement of DTs for TANGEDCO

Estimated Repair Cost

As-Is Repair Costs

Labour and Transpotation Cost for As-Is Repair	INR	2,700.00
Material Cost for As-Is Repair	INR	20,246.40
Total Cost for As-Is Repair	INR	22,946.40

To-Be Repair Costs

Labour Cost for To-Be Repair	INR	2,700.00
Material Cost for To-Be Repair (using Copper)	INR	66,230.07
Total Cost for To-Be Repair	INR	68,930.07

Incremental cost for To-Be Active Repair over and above Normal Repair	INR	45,983.67
---	-----	-----------

Project Payback

	0	1	2	3	4	5	6	7	8	9	10
Cash inflow	-	12,859	14,145	15,559	17,115	18,826	20,709	22,780	25,058	27,564	84,575
Cumulative cash inflow	-	12,859	27,003	42,562	59,677	78,503	99,212	1,21,992	1,47,050	1,74,614	2,59,188
Cash Outflow	45,983.67										
Cumulative cash outflow	45,984	45,984	45,984	45,984	45,984	45,984	45,984	45,984	45,984	45,984	45,984
Payback ratio		0.28	0.59	0.93	1.30	1.71	2.16	2.65	3.20	3.80	5.64
		-		-	1.00	1.00	1.00	1.00	1.00	1.00	1.00
		-		-	1.00	-	-	-	-	-	-
		-	-	-	3.20	-	-	-	-	-	-

Active Repair for Performance Improvement of DTs for TANGEDCO

Annexure-5: Sensitivity to Cu Salvage value at the end of service

Without Cu Salvage Value

Project IRR											
	Year0	Year1	Year2	Year3	Year4	Year5	Year6	Year7	Year8	Year9	Year10
Cash Inflow		28,859	14,145	15,559	17,115	18,826	20,709	22,780	25,058	27,564	30,320
Cash inflow from Salvage value											-
Cash outflow	45,983.67										
Net Cash Inflow	(45,984)	28,859	14,145	15,559	17,115	18,826	20,709	22,780	25,058	27,564	30,320
Discount factor	10%										
	100%	91%	83%	75%	68%	62%	56%	51%	47%	42%	39%
NPV of cash inflow	(45,983.67)	26,235.13	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68
WACC	9.43%										
ProJECT IRR	44.42%	31.29%									

With Cu Salvage Value

Project IRR											
	Year0	Year1	Year2	Year3	Year4	Year5	Year6	Year7	Year8	Year9	Year10
Cash Inflow		28,859	14,145	15,559	17,115	18,826	20,709	22,780	25,058	27,564	30,320
Cash inflow from Salvage value											54,255
Cash outflow	45,983.67										
Net Cash Inflow	(45,984)	28,859	14,145	15,559	17,115	18,826	20,709	22,780	25,058	27,564	84,575
Discount factor	10%										
	100%	91%	83%	75%	68%	62%	56%	51%	47%	42%	39%
NPV of cash inflow	(45,983.67)	26,235.13	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	11,689.68	32,607.25
WACC	9.43%										
ProJECT IRR	45.81%	32.56%									

Note: INR. 28,859 is the sum of net savings (Savings from transformer, Increased kVA Capacity Capex Savings, Interest On Term Loan) and financing costs (interest to be paid on 70% debt on incremental cost of repair) in year-1

Annexure-6: Energy Efficiency Level as per IS 1180:2014

Sl No.	Rating (kVA)	Impedance (Percent)	Maximum Total Loss (W)					
			Energy Efficiency Level 1		Energy Efficiency Level 2		Energy Efficiency Level 3	
			50 % Load	100 % Load	50 % Load	100 % Load	50 % Load	100 % Load
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
i)	6.3	4.0	53	245	48	225	42	205
ii)	10	4.5	72	270	65	240	58	215
iii)	16	4.5	150	480	135	440	120	400
iv)	20	4.5	175	575	160	525	145	485
v)	25	4.5	210	695	190	635	175	595
vi)	40	4.5	277	914	249	834	224	774
vii)	63	4.5	380	1 250	340	1 140	300	1 050
viii)	100	4.5	520	1 800	475	1 650	435	1 500
ix)	160	4.5	770	2 200	670	1 950	570	1 700
x)	200	4.5	890	2 700	780	2 300	670	2 100

Maximum allowable losses at PGVCL**LOSSES OF LABELED TRANSFORMERS IN WATTS**

Capacity in KVA	5	10	16	25	63	100	200	500
Energy Efficiency Level -1								
Maximum No Load Losses	15	45	60	75	150	200	310	550
Maximum total losses at 50% loading	40	72	150	210	380	520	890	1600
Maximum *total losses at 100% loading	115	270	480	695	1250	1800	2700	4750
Energy Efficiency Level -2								
Maximum No Load Losses	15	40	50	60	125	170	270	545
Maximum total losses at 50% loading	35	65	135	190	340	475	780	1510
Maximum *total losses at 100% loading	95	240	440	635	1140	1650	2300	4300

*Total Losses in watt at 100 % loading = No Load losses in watt + Full Load losses in watt at 75 Deg. C

EE-1: At 100% loading, Full load loss = Total Loss- No load loss = 1800-200= 1600W

EE-2: At 100% loading, Full load loss = Total Loss- No load loss = 1650-170= 1480W

Annexure-7: Applicability to broader TANGEDCO Utility

39

Acknowledgement

 <p>TANGEDCO</p>	<ul style="list-style-type: none"> • Director Distribution • Chief Engineer R&D • Superintendent Engineer R&D • Executive Engineer R&D • R&D Department
 <p>International Copper Association India Copper Alliance</p>	<ul style="list-style-type: none"> • Mr. Manas Kundu, Director, Energy Solutions • Mr. Mayur Karmarkar, Regional Director Sustainable Energy • Mr. Baskar Sivaraman, ICAI Associate
<p>TRISTAR TECHNOCRATES</p>  <p>(Transformers Design Consultants)</p>	<ul style="list-style-type: none"> • Mr. Rajesh Joshi, Transformer Design Expert
 <p>SAKTHI TRANSFORMERS (ISI CERTIFIED COMPANY)</p>	<ul style="list-style-type: none"> • Utility Nominated Transformer Repairer